

Consumer Confidence Report

Annual Drinking Water Quality Report

DWIGHT

IL1050250

Annual Water Quality Report for the period of January 1 to December 31, 2025

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

The source of drinking water used by DWIGHT is Ground Water

For more information regarding this report contact:

Name JOSEPH FRITSCH

Phone 815-584-1128

Este informe contiene información muy importante sobre el agua que usted bebe. Tradúzcalo ó hable con alguien que lo entienda bien.

Source of Drinking Water
The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.
Contaminants that may be present in source water include: <ul style="list-style-type: none">- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPAs Safe Drinking Water Hotline at (800) 426-4791.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The drinking water supplier is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standard Institute accredited certifier

to reduce lead in drinking water. If you are concerned about lead in your water, you may wish to have your water tested, contact JOSEPH FRITSCH at 815-584-1128. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

Source Water Information

Source Water Name		Type of Water	Report Status	Location
WELL 7 (40020)	CORNER OF SOUTH AND	GW	<u>ACTIVE</u>	<u>SE CORNER SOUTH AND WASHINGTON</u>
WELL 8 (00357)	W OF CORNER OF DELAWARE	GW	<u>ACTIVE</u>	<u>SW CORNER DELAWARE AND S. OLD RT 66</u>
WELL 9 (01069)	NW CORNER FRANKLIN AND	GW	<u>ACTIVE</u>	<u>NW CORNER CHIPPEWA AND FRANKLIN</u>

Source Water Assessment

We want our valued customers to be informed about their water quality. If you would like to learn more, please feel welcome to attend any of our regularly scheduled meetings. The source water assessment for our supply has been completed by the Illinois EPA. If you would like a copy of this information, please stop by City Hall or call our water operator at 815-584-1128. To view a summary version of the completed Source Water Assessments, including: Importance of Source Water; Susceptibility to Contamination Determination; and documentation/recommendation of Source Water Protection Efforts, you may access the Illinois EPA website at <http://www.epa.state.il.us/cgi-bin/wp/swap-fact-sheets.pl>.

Source of Water: DWIGHT To determine Dwight's susceptibility to groundwater contamination, a Well Site Survey, published in 1992 by the Illinois EPA, and a Source Water Assessment Program, were reviewed. Based on the information contained in these documents, six potential sources of groundwater contamination are present that could pose a hazard to groundwater pumped by the Dwight community water supply wells. These include a foundry/metal working, two vehicle sales, and three below ground fuel storages. Based on information obtained by Dwight water supply officials, the following facilities, also indicated as potential sources in the site data table, have had their tanks removed: Dempsey Dodge Chrysler Plymouth (now Public Service Complex), Tri Oil Station, TD Petroleum, Arthur Leach, and the Village of Dwight, Rub Buick Chevrolet Oldsmobile, Phillip Becker, and unknown underground fuel storage. Based upon this information, the Illinois EPA has determined that Dwight Wells #7, #8, and #9 are not susceptible to IOC, VOC, or SOC contamination. Based on their proposed construction and location, the Illinois EPA anticipates that proposed Well #101 will not be susceptible to IOC, VOC, or SOC contamination when it comes on line. This determination is based on a number of criteria including: monitoring conducted at the wells; monitoring conducted at the entry point to the distribution system; and the available hydrogeologic data for the wells. In anticipation of the U.S. EPA's proposed Ground Water Rule, the Illinois EPA has determined that Dwight's community water supply wells are not vulnerable to viral contamination. This determination is based upon the evaluation of the following criteria during the Vulnerability Waiver Process: the community's wells are properly constructed with sound integrity and proper site conditions; there is a hydrogeologic barrier that restricts pathogen movement; all potential routes and sanitary defects have been mitigated such that the source water is adequately protected; monitoring data did not indicate a history of disease outbreak; and the sanitary survey of the water supply did not indicate a viral contamination threat. However, having stated this, the U.S. EPA is proposing to require States to identify systems in karst, gravel and fractured rock aquifer systems as sensitive. Water systems utilizing these aquifer types would be required to perform routine source water monitoring. Because the community's wells are constructed in a confined aquifer, which should provide an adequate degree of protection to prevent the movement of pathogens into the wells, well hydraulics were not considered to be a significant factor in the vulnerability determination.

Lead and Copper

Definitions:
 Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
 Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Copper Range: 0.007 ppb to 1.500 ppb
 Lead Range: Less than 1.0 ppb to 1.7 ppb

To obtain a copy of the system's lead tap sampling data: CONTACT WATER OPERATOR 815-584-1128

CIRCLE ONE: Our Community Water Supply **has** has not developed a service line material inventory.
 To obtain a copy of the system's service line inventory: CONTACT WATER OPERATOR 815-584-1128

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	2025	1.3	1.3	0.85	0	ppm	N	Corrosion of household plumbing systems; Erosion of natural deposits.

Water Quality Test Results

Definitions: The following tables contain scientific terms and measures, some of which may require explanation.

Avg: Regulatory compliance with some MCLs are based on running annual average of monthly samples.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum Contaminant Level or MCL: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum residual disinfectant level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum residual disinfectant level goal or MRDLG: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

na: not applicable.

Water Quality Test Results

mrem: millirems per year (a measure of radiation absorbed by the body)

ppb: micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.

ppm: milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.

Treatment Technique or TT: A required process intended to reduce the level of a contaminant in drinking water.

MRL MINIMUM REPORTING LEVEL

Regulated Contaminants

Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Chlorine	2025	2	1.8 - 2	MRDLG = 4	MRDL = 4	ppm	N	Water additive used to control microbes.
Haloacetic Acids (HAA5)	2025	31	30.7 - 30.7	No goal for the total	60	ppb	N	By-product of drinking water disinfection.
Total Trihalomethanes (TTHM)	2025	73	73.4 - 73.4	No goal for the total	80	ppb	N	By-product of drinking water disinfection.
Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Arsenic - While your drinking water meets EPA standards for arsenic, it does contain low levels of arsenic. EPAs standard balances the current understanding of arsenics possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.	2025	9	7.5 - 9.6	0	10	ppb	N	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes.
Barium	09/04/2024	0.31	0.077 - 0.31	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Fluoride	09/04/2024	0.573	0.425 - 0.573	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Iron	09/04/2024	1.8	1.7 - 1.8		1.0	ppm	N	This contaminant is not currently regulated by the USEPA. However, the state regulates. Erosion of natural deposits.

Manganese	2025	93	79 - 110	150	150	ppb	N	This contaminant is not currently regulated by the USEPA. However, the state regulates. Erosion of natural deposits.
Nitrate [measured as Nitrogen]	2025	2	0 - 2	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Selenium	09/04/2024	3.4	1 - 3.4	50	50	ppb	N	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines.
Sodium	09/04/2024	230	160 - 230			ppb	N	Erosion from naturally occurring deposits. Used in water softener regeneration.
Zinc	09/04/2024	0.0068	0 - 0.0068	5	5	ppm	N	This contaminant is not currently regulated by the USEPA. However, the state regulates. Naturally occurring; discharge from metal
Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Combined Radium 226/228	2025	0.66	0.66 - 0.66	0	5	pCi/L	N	Erosion of natural deposits.

UNREGULATED CONTAMINANTS

MONITORING RESULTS FINISHED WATER TAP07 – TP07

ANALYTE/CONTAMINANT	DATE COLLECTED	LEVEL DETECTED
Lithium	2/3/2025	<MRL
11CI-PF3OUdS	2/3/2025	<MRL
4:2 FTS	2/3/2025	<MRL
6:2 FTS	2/3/2025	<MRL
8:2 FTS	2/3/2025	<MRL
9CI-PF3ONS	2/3/2025	<MRL
ADONA	2/3/2025	<MRL
HFPO-DA	2/3/2025	<MRL
NFDHA	2/3/2025	<MRL
PFBA	2/3/2025	<MRL
PFBS	2/3/2025	<MRL
PFDA	2/3/2025	<MRL
PFDoA	2/3/2025	<MRL
PFEESA	2/3/2025	<MRL
PFHpA	2/3/2025	<MRL
PFHpS	2/3/2025	<MRL
PFHxA	2/3/2025	<MRL
PFHxS	2/3/2025	<MRL
PFMPA	2/3/2025	<MRL
PFNA	2/3/2025	<MRL
PFOA	2/3/2025	<MRL
PFOS	2/3/2025	<MRL
PFPeA	2/3/2025	<MRL
PFPeS	2/3/2025	<MRL
PFUnA	2/3/2025	<MRL
NEtFOSAA	2/3/2025	<MRL

NMeFOSAA	2/3/2025	<MRL
PFTA	2/3/2025	<MRL
PFTrDA	2/3/2025	<MRL
Lithium	8/4/2025	<MRL
11CI-PF3OUdS	8/4/2025	<MRL
4:2 FTS	8/4/2025	<MRL
6:2 FTS	8/4/2025	<MRL
8:2 FTS	8/4/2025	<MRL
9CI-PF3ONS	8/4/2025	<MRL
ADONA	8/4/2025	<MRL
HFPO-DA	8/4/2025	<MRL
NFDHA	8/4/2025	<MRL
PFBA	8/4/2025	<MRL
PFBS	8/4/2025	<MRL
PFDA	8/4/2025	<MRL
PFDoA	8/4/2025	<MRL
PFEESA	8/4/2025	<MRL
PFHpA	8/4/2025	<MRL
PFHpS	8/4/2025	<MRL
PFHxA	8/4/2025	<MRL
PFHxS	8/4/2025	<MRL
PFMBA	8/4/2025	<MRL
PFMPA	8/4/2025	<MRL
PFNA	8/4/2025	<MRL
PFOA	8/4/2025	<MRL
PFOS	8/4/2025	<MRL
PFPeA	8/4/2025	<MRL
PFPeS	8/4/2025	<MRL
PFUnA	8/4/2025	<MRL
NEtFOSAA	8/4/2025	<MRL

NMeFOSAA	8/4/2025	<MRL
PFTA	8/4/2025	<MRL
PFTTrDA	8/4/2025	<MRL